

**Table 1. Trigger Water Level Elevations for Chamberlain Springs Large Groundwater Withdrawal Permit 2006-002**

Town Map / Lot Number	180-day No-Recharge Drawdown (feet MSL)	Stage I Trigger Level (feet MSL)	Stage II Trigger Level (feet MSL)	Stage III Trigger Level (feet MSL)	Address
8-39	700	690	680	670	93 Old Wolfeboro Road
9-60	731	721	711	701	103 Range Road
9-60-6 <sup>1</sup>	0	Note 1	Note 1	Note 1	137 Range Road
9-60-1 <sup>1</sup>	0	Note 1	Note 1	Note 1	81 Range Road
12-13	752	742	732	722	Bay Hill Road
12-50	774	764	754	744	Old Wolfeboro Road
12-54-1	826	816	806	796	Old Wolfeboro Road
12-53-1	736	726	716	706	178 Old Wolfeboro Road
12-53-2 (old)	719	709	699	689	169 Old Wolfeboro Road
12-53-2 (new)	859	849	839	829	169 Old Wolfeboro Road
12-53-3	830	820	810	800	42 Clark Road
12-55	756	746	736	726	140 Old Wolfeboro Road
12-57	828	818	808	798	166 Old Wolfeboro Road

**NOTES:**

1. Static water level for these wells shall be determined at the time monitoring begins. Stage I, II and III trigger levels shall be established based on static water levels and observations following start of monitoring.
2. If an alternative monitoring location is used as described in Section 5 then the trigger levels shall be established in Note 1. above.